



- Drawing Notes:**
- All dimensions are shown in metre unless noted otherwise.
 - Do not scale from this drawing.
 - Fire water tanks are to feed a fire water ring main that limits the distance from any internal hydrant to the BESS equipment to less than 90m.
- Legend:**
- Planning Boundary
 - Cable Route
 - Palisade Fencing
 - 4.5m Acoustic Fencing
 - Stock Proof Fencing
 - Attenuation Basin
 - Access Road - Unbound Finish
 - Access Road - Bound Finish
 - Landscaping Bunds
 - Landscaping - refer to Landscape Mitigation Plan (1005-SHRSK-XX-XX-DR-L-1000)
 - Existing Forestry (to be retained)
 - Information Identification
 - Hazard Identification

00	27.03.2025	Fire Safety Plan - Original	JH	AP
REV	DATE	DESCRIPTION	BY	CHKD




Field
Fora Montacute Yards
186 Shoreditch High Street
London
E1 6HU

PROJECT
New Deer

TITLE
Fire Safety Plan

DISCIPLINE PLANNING				
DRAWING STATUS FOR PLANNING				
SCALE 1:2,000 @A1	DATE 27.03.2025	DRAWN BY JH	CHECKED BY AP	APPROVED BY RS
PROJECT NO. BTGBNDE02	DRAWING NO. 005.6	REV. 00		



1:100	1m	2m	3m	4m	5m	6m	7m	8m	9m	10m
1:200		5m	10m	15m	20m	25m	30m	35m	40m	45m
1:250			10m	20m	30m	40m	50m	60m	70m	80m
1:500				20m	40m	60m	80m	100m	120m	140m
1:1000					40m	80m	120m	160m	200m	240m
1:2000						80m	160m	240m	320m	400m
1:2500							160m	240m	320m	400m
1:5000								320m	400m	500m